



KNOXVILLE DIVISION
 505 EAST BROADWAY AVE.
 MARYVILLE, TN 37804
 (865) 977-1200 FAX (865) 984-8616
 http://www.microbac.com
 E-Mail: knoxville@microbac.com

STATE CERT ID.
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS

CITY OF KINGSTON
 CHUCK MOORE
 125 W. CUMBERLAND ST.
 KINGSTON, TN 37763

Date Reported 2/17/2010
 Date Received 1/27/2010
 Cust P.O.
 Invoice No. 78750
 Cust # C120
 Sample Date 1/27/2010
 Permit No. 0000360

Work Order Number: 1001-00933

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

| Test | Method | Result | Qual | Date | Time | Tech |
|-----------------------------|-------------------|--------------|-------|------------|-------|------|
| 001 RAW 1/27/10 0630 | | | | | | |
| [TAL METALS] | | | | 02/01/2010 | 14:41 | SRR |
| ALUMINUM | EPA 200.7 | 0.360 MG/L | J+, N | 01/28/2010 | 17:01 | SRR |
| ANTIMONY | EPA 200.8 | <0.005 MG/L | | 02/01/2010 | 14:41 | MTC |
| ARSENIC | EPA 200.8 | <0.005 MG/L | | 02/01/2010 | 14:41 | MTC |
| BARIUM | EPA 200.7 | 0.0231 MG/L | N | 01/28/2010 | 17:01 | SRR |
| BERYLLIUM | EPA 200.7 | <0.0010 MG/L | | 01/28/2010 | 17:01 | SRR |
| CADMIUM | EPA 200.7 | <0.0010 MG/L | | 01/28/2010 | 17:01 | SRR |
| CHROMIUM | EPA 200.7 | <0.0010 MG/L | | 01/28/2010 | 17:01 | SRR |
| COBALT | EPA 200.7 | <0.0010 MG/L | | 01/28/2010 | 17:01 | SRR |
| COPPER | EPA 200.7 | <0.0010 MG/L | | 01/28/2010 | 17:01 | SRR |
| IRON | EPA 200.7 | 0.467 MG/L | N | 01/28/2010 | 17:01 | SRR |
| LEAD | EPA 200.8 | <0.005 MG/L | | 02/01/2010 | 14:41 | MTC |
| MAGNESIUM | EPA 200.7 | 4.16 MG/L | N | 01/28/2010 | 17:01 | SRR |
| MANGANESE | EPA 200.7 | 0.0362 MG/L | N | 01/28/2010 | 17:01 | SRR |
| MOLYBDENUM | EPA 200.7 | <0.0010 MG/L | | 01/28/2010 | 17:01 | SRR |
| MERCURY | EPA 245.1 | <0.0002 MG/L | | 01/28/2010 | 11:56 | SRR |
| NICKEL | EPA 200.7 | <0.0010 MG/L | | 01/28/2010 | 17:01 | SRR |
| SELENIUM | EPA 200.8 | <0.005 MG/L | | 02/01/2010 | 14:41 | MTC |
| SILVER | EPA 200.7 | <0.0010 MG/L | | 01/28/2010 | 17:01 | SRR |
| TIN | EPA 200.7 | <0.0010 MG/L | | 01/28/2010 | 17:01 | SRR |
| TITANIUM | EPA 200.7 | 0.0066 MG/L | | 01/28/2010 | 17:01 | SRR |
| THALLIUM | EPA 200.8 | <0.001 MG/L | | 02/01/2010 | 14:41 | MTC |
| ZINC | EPA 200.7 | 0.0229 MG/L | N | 01/28/2010 | 17:01 | SRR |
| BORON | EPA 200.7 | 0.0095 MG/L | | 01/28/2010 | 17:01 | SRR |
| SOLIDS, TOTAL SUSPENDED | SM 2540,D. | 8.06 MG/L | | 01/27/2010 | 09:00 | KDW |
| HARDNESS, TOTAL AS CaCO3 | EPA 200.7;2340,B. | 61.1 MG/L | N | 01/28/2010 | 17:01 | SRR |

002 RAW 1/27/10 0630 DISSOLVED METALS





KNOXVILLE DIVISION
505 EAST BROADWAY AVE.
MARYVILLE, TN 37804
(865) 977-1200 FAX (865) 984-8616
http://www.microbac.com
E-Mail: knoxville@microbac.com

STATE CERT ID.
TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS

CITY OF KINGSTON
CHUCK MOORE
125 W. CUMBERLAND ST.
KINGSTON, TN 37763

Date Reported 2/17/2010
Date Received 1/27/2010
Cust P.O.
Invoice No. 78750
Cust # C120
Sample Date 1/27/2010
Permit No. 0000360

Work Order Number: 1001-00933

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test Method Result Qual Date Time Tech

002 RAW 1/27/10 0630 DISSOLVED METALS

.....continued

[TAL METALS]

Table with 7 columns: Test, Method, Result, Qual, Date, Time, Tech. Rows include ALUMINUM, ANTIMONY, ARSENIC, BARIUM, BERYLLIUM, CADMIUM, CHROMIUM, COBALT, COPPER, IRON, LEAD, MAGNESIUM, MANGANESE, MOLYBDENUM, MERCURY, NICKEL, SELENIUM, SILVER, TIN, TITANIUM, THALLIUM, ZINC, BORON, SILICA (SiO2).

003 FINISHED 1/27/10 0630





KNOXVILLE DIVISION
505 EAST BROADWAY AVE.
MARYVILLE, TN 37804
(865) 977-1200 FAX (865) 984-8616
http://www.microbac.com
E-Mail: knoxville@microbac.com

STATE CERT ID.
TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS

CITY OF KINGSTON
CHUCK MOORE
125 W. CUMBERLAND ST.
KINGSTON, TN 37763

Date Reported 2/17/2010
Date Received 1/27/2010
Cust P.O.
Invoice No. 78750
Cust # C120
Sample Date 1/27/2010
Permit No. 0000360

Work Order Number: 1001-00933

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Table with 7 columns: Test, Method, Result, Qual, Date, Time, Tech. Contains data for various metals and solids tests.

004 FINISHED 1/27/10 0630 DISSOLVED METALS





KNOXVILLE DIVISION
505 EAST BROADWAY AVE.
MARYVILLE, TN 37804
(865) 977-1200 FAX (865) 984-8616
http://www.microbac.com
E-Mail: knoxville@microbac.com

STATE CERT ID.
TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS

CITY OF KINGSTON
CHUCK MOORE
125 W. CUMBERLAND ST.
KINGSTON, TN 37763

Date Reported 2/17/2010
Date Received 1/27/2010
Cust P.O.
Invoice No. 78750
Cust # C120
Sample Date 1/27/2010
Permit No. 0000360

Work Order Number: 1001-00933

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Table with 7 columns: Test, Method, Result, Qual, Date, Time, Tech. Row 1: 004 FINISHED 1/27/10 0630 DISSOLVED METALS. Rows 2-31: List of metals (ALUMINUM, ANTIMONY, ARSENIC, etc.) with their respective test methods, results, and dates.

REVISED REPORT TO CONTAIN BACK-UP STATE CERTIFIED DATA FOR SB, AS, PB, SE AND TL. ANALYSIS SUBCONTRACTED TO MICROBAC LABORATORIES TRI-CITIES DIVISION (TN LAB ID#04017). LL 02-17-10.





KNOXVILLE DIVISION
505 EAST BROADWAY AVE.
MARYVILLE, TN 37804
(865) 977-1200 FAX (865) 984-8616
http://www.microbac.com
E-Mail: knoxville@microbac.com

STATE CERT ID.
TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS

CITY OF KINGSTON
CHUCK MOORE
125 W. CUMBERLAND ST.
KINGSTON, TN 37763

Date Reported 2/17/2010
Date Received 1/27/2010
Cust P.O.
Invoice No. 78750
Cust # C120
Sample Date 1/27/2010
Permit No. 0000360

Work Order Number: 1001-00933

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Table with 7 columns: Test, Method, Result, Qual, Date, Time, Tech

RESPECTFULLY SUBMITTED:

MICROBAC LABORATORIES, INC.

Thank you for your business. We invite your feedback on our level of service to you. Please contact the Laboratory Director, Ashley Morris, at 865-977-1200, the COO, Robert Morgan, at rmorgan@microbac.com or the President, James Nokes, at jnokes@microbac.com with any comments or suggestions.





KNOXVILLE DIVISION
505 EAST BROADWAY AVE.
MARYVILLE, TN 37804
(865) 977-1200 FAX (865) 984-8616
http://www.microbac.com
E-Mail: knoxville@microbac.com

STATE CERT ID.
TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS

CITY OF KINGSTON
CHUCK MOORE
125 W. CUMBERLAND ST.
KINGSTON, TN 37763

Date Reported 2/17/2010
Date Received 1/27/2010
Cust P.O.
Invoice No. 78750
Cust # C120
Sample Date 1/27/2010
Permit No. 0000360

Work Order Number: 1001-00933

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Table with 7 columns: Test, Method, Result, Qual, Date, Time, Tech

As regulatory limits change frequently, Microbac advises the recipient of this report to confirm such limits with the appropriate Federal, state, or local authorities before acting in reliance on the regulatory limits provided.

Microbac Laboratories, Inc. cannot guarantee the confidentiality of any facsimile or e-mail transmittal. The information in this communication is intended for the exclusive use of the addressee. If you are not the intended recipient, you are notified that any disclosure, copying, distributing, or the taking of any action in reliance on the contents of this information is strictly prohibited.

QUALIFIER DEFINITIONS:

- B = Detected in the associated Method Blank
C = As Tons CaCO3, equivalent per 1,000 tons material
D = Surrogate recoveries not calculated due to matrix interference and resulting sample dilution
E1 = Elevated detection limits due to sample matrix interference
E2 = Elevated detection limits due to high analyte concentration
H = Analyte was prepared and/or analyzed outside of the analytical method holding time
I = Spike recovery outside control limits due to sample matrix interference or high analyte concentration
J = The result is an estimated quantity. The associated numerical value is the approximate concentration of the analyte in the sample
J+ = The result is an estimated quantity, but the result may be biased high
J- = The result is an estimated quantity, but the result may be biased low
UJ = The analyte was analyzed for, but was not detected. The reported quantitation limit is approximate and may be inaccurate or imprecise
K = Inter-element correction applied due to high concentration of non-target analyte
L1 = Liquid portion of dual phase sample analyzed only
L2 = Solid portion of dual phase sample analyzed only
M = Miscellaneous (see entry below analytical results)
N = Analyte acceptable but matrix spike/matrix spike duplicate outside accepted recovery criteria
* = Matrix Spike/Matrix Spike Duplicate RPD is outside acceptable limits
P = Sample received improperly preserved
R = Relative Percent Duplicate (RPD) outside accepted recovery limits
S1 = Spike recovery outside recovery limits
S2 = Surrogate recovery outside of control limits. The data was accepted based on the valid recovery of remaining surrogate.
U = Undetected
V = Elevated reporting limits due to insufficient sample volume
W = Results reports on dry weight basis
Z = The parameter is considered a field analysis with an immediate to 15 minute holding time. Laboratory analysis is confirmatory in nature and is performed outside the preferred holding time window.

ABBREVIATIONS:

- TNTC = Too Numerous To Count
MG/KG = Milligrams per Kilogram (PPM)
UG/L = Micrograms per Liter (PPB)
CFU = Colony Forming Unit

