



Microbac Laboratories, Inc.

KNOXVILLE DIVISION
505 EAST BROADWAY AVE.
MARYVILLE, TN 37804
(865) 977-1200 FAX (865) 984-8616
http://www.microbac.com
E-Mail: knoxville@microbac.com

STATE CERT ID.
TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
WATER · AIR · WASTES · FOOD · PHARMAUTICALS · NUTRACEUTICALCES

CERTIFICATE OF ANALYSIS

CITY OF KINGSTON
CHUCK MOORE
125 W. CUMBERLAND ST.
KINGSTON, TN 37763

Date Reported 1/5/2010
Date Received 12/23/2009
Cust P.O.
Invoice No. 77098
Cust # C120
Sample Date 12/23/2009
Permit No. 0000360

Work Order Number: 0912-01048

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Table with 7 columns: Test, Method, Result, Qual, Date, Time, Tech. Contains data for RAW 12/23/09 0630 including various metal tests like ALUMINUM, ANTIMONY, ARSENIC, etc.

002 RAW 12/23/09 0630 DISSOLVED METALS





KNOXVILLE DIVISION  
 505 EAST BROADWAY AVE.  
 MARYVILLE, TN 37804  
 (865) 977-1200 FAX (865) 984-8616  
 http://www.microbac.com  
 E-Mail: knoxville@microbac.com

STATE CERT ID.  
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS  
 WATER · AIR · WASTES · FOOD · PHARMAUTICALS · NUTRACEUTICALCES

**CERTIFICATE OF ANALYSIS**

CITY OF KINGSTON  
 CHUCK MOORE  
 125 W. CUMBERLAND ST.  
 KINGSTON, TN 37763

Date Reported 1/5/2010  
 Date Received 12/23/2009  
 Cust P.O.  
 Invoice No. 77098  
 Cust # C120  
 Sample Date 12/23/2009  
 Permit No. 0000360

Work Order Number: 0912-01048

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
------	--------	--------	------	------	------	------

002 **RAW 12/23/09 0630 DISSOLVED METALS**  
 .....continued

[ TAL METALS ]				12/30/2009	13:20	SRR
ALUMINUM	EPA 200.7	0.0269 MG/L		12/28/2009	15:01	SRR
ANTIMONY	EPA 200.8	<0.005 MG/L		12/30/2009	13:20	MCD
ARSENIC	EPA 200.8	<0.005 MG/L		12/30/2009	13:20	MCD
BARIUM	EPA 200.7	0.0180 MG/L		12/28/2009	15:01	SRR
BERYLLIUM	EPA 200.7	<0.0010 MG/L		12/28/2009	15:01	SRR
CADMIUM	EPA 200.7	<0.0010 MG/L		12/28/2009	15:01	SRR
CHROMIUM	EPA 200.7	<0.0010 MG/L		12/28/2009	15:01	SRR
COBALT	EPA 200.7	<0.0010 MG/L		12/28/2009	15:01	SRR
COPPER	EPA 200.7	<0.0010 MG/L		12/28/2009	15:01	SRR
IRON	EPA 200.7	0.0454 MG/L		12/28/2009	15:01	SRR
LEAD	EPA 200.8	<0.005 MG/L		12/30/2009	13:20	MCD
MAGNESIUM	EPA 200.7	3.85 MG/L		12/28/2009	14:06	SRR
MANGANESE	EPA 200.7	<0.0050 MG/L		12/28/2009	15:01	SRR
MOLYBDENUM	EPA 200.7	<0.0010 MG/L		12/28/2009	15:01	SRR
MERCURY	EPA 245.1	<0.0002 MG/L		12/28/2009	13:37	SRR
NICKEL	EPA 200.7	<0.0010 MG/L		12/28/2009	15:01	SRR
SELENIUM	EPA 200.8	<0.005 MG/L		12/30/2009	13:20	MCD
SILVER	EPA 200.7	<0.0010 MG/L	J-	12/28/2009	15:01	SRR
TIN	EPA 200.7	<0.0010 MG/L		12/28/2009	15:01	SRR
TITANIUM	EPA 200.7	<0.0010 MG/L		12/28/2009	15:01	SRR
THALLIUM	EPA 200.8	<0.001 MG/L		12/30/2009	13:20	MCD
ZINC	EPA 200.7	0.0159 MG/L		12/28/2009	15:01	SRR
BORON	EPA 200.7	0.0022 MG/L	J-	12/28/2009	15:01	SRR
SILICA (SiO2)	EPA 200.7	2.86 MG/L	J+	12/28/2009	14:06	SRR

003 **FINISHED 12/23/09 0630**





Microbac Laboratories, Inc.

KNOXVILLE DIVISION
505 EAST BROADWAY AVE.
MARYVILLE, TN 37804
(865) 977-1200 FAX (865) 984-8616
http://www.microbac.com
E-Mail: knoxville@microbac.com

STATE CERT ID.
TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
WATER · AIR · WASTES · FOOD · PHARMAUTICALS · NUTRACEUTICALCES

CERTIFICATE OF ANALYSIS

CITY OF KINGSTON
CHUCK MOORE
125 W. CUMBERLAND ST.
KINGSTON, TN 37763

Date Reported 1/5/2010
Date Received 12/23/2009
Cust P.O.
Invoice No. 77098
Cust # C120
Sample Date 12/23/2009
Permit No. 0000360

Work Order Number: 0912-01048

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test Method Result Qual Date Time Tech

003 FINISHED 12/23/09 0630

.....continued

Table with 7 columns: Test, Method, Result, Qual, Date, Time, Tech. Rows include various metals like ALUMINUM, ANTIMONY, ARSENIC, etc., with their respective test methods and results.

004 FINISHED 12/23/09 0630 DISSOLVED METALS





**Microbac Laboratories, Inc.**

KNOXVILLE DIVISION  
 505 EAST BROADWAY AVE.  
 MARYVILLE, TN 37804  
 (865) 977-1200 FAX (865) 984-8616  
 http://www.microbac.com  
 E-Mail: knoxville@microbac.com

STATE CERT ID.  
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS  
 WATER · AIR · WASTES · FOOD · PHARMAUTICALS · NUTRACEUTICALCES

**CERTIFICATE OF ANALYSIS**

CITY OF KINGSTON  
 CHUCK MOORE  
 125 W. CUMBERLAND ST.  
 KINGSTON, TN 37763

Date Reported 1/5/2010  
 Date Received 12/23/2009  
 Cust P.O.  
 Invoice No. 77098  
 Cust # C120  
 Sample Date 12/23/2009  
 Permit No. 0000360

Work Order Number: 0912-01048

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
------	--------	--------	------	------	------	------

004 **FINISHED 12/23/09 0630 DISSOLVED METALS**

[ TAL METALS ]				12/30/2009	13:28	SRR
ALUMINUM	EPA 200.7	0.0128 MG/L		12/28/2009	15:08	SRR
ANTIMONY	EPA 200.8	<0.005 MG/L		12/30/2009	13:28	MCD
ARSENIC	EPA 200.8	<0.005 MG/L		12/30/2009	13:28	MCD
BARIUM	EPA 200.7	0.0178 MG/L		12/28/2009	15:08	SRR
BERYLLIUM	EPA 200.7	<0.0010 MG/L		12/28/2009	15:08	SRR
CADMIUM	EPA 200.7	<0.0010 MG/L		12/28/2009	15:08	SRR
CHROMIUM	EPA 200.7	<0.0010 MG/L		12/28/2009	15:08	SRR
COBALT	EPA 200.7	<0.0010 MG/L		12/28/2009	15:08	SRR
COPPER	EPA 200.7	0.0018 MG/L		12/28/2009	15:08	SRR
IRON	EPA 200.7	<0.0060 MG/L		12/28/2009	15:08	SRR
LEAD	EPA 200.8	<0.005 MG/L		12/30/2009	13:28	MCD
MAGNESIUM	EPA 200.7	3.89 MG/L		12/28/2009	14:13	SRR
MANGANESE	EPA 200.7	<0.0050 MG/L		12/28/2009	15:08	SRR
MOLYBDENUM	EPA 200.7	<0.0010 MG/L		12/28/2009	15:08	SRR
MERCURY	EPA 245.1	<0.0002 MG/L		12/28/2009	13:37	SRR
NICKEL	EPA 200.7	<0.0010 MG/L		12/28/2009	15:08	SRR
SELENIUM	EPA 200.8	<0.005 MG/L		12/30/2009	13:28	MCD
SILVER	EPA 200.7	<0.0010 MG/L	J-	12/28/2009	15:08	SRR
TIN	EPA 200.7	<0.0010 MG/L		12/28/2009	15:08	SRR
TITANIUM	EPA 200.7	<0.0010 MG/L		12/28/2009	15:08	SRR
THALLIUM	EPA 200.8	<0.001 MG/L		12/30/2009	13:28	MCD
ZINC	EPA 200.7	0.0045 MG/L		12/28/2009	15:08	SRR
BORON	EPA 200.7	0.0023 MG/L	J-	12/28/2009	15:08	SRR
SILICA (SiO2)	EPA 200.7	6.46 MG/L	J+	12/28/2009	14:13	SRR

**REVISED REPORT TO CONTAIN BACK-UP STATE CERTIFIED DATA FOR SB, AS, PB, SE AND TL. ANALYSIS SUBCONTRACTED TO MICROBAC LABORATORIES CHICAGOLAND DIVISION (TN LAB ID#04017). LL 01-05-10.**





® **Microbac Laboratories, Inc.**

KNOXVILLE DIVISION  
505 EAST BROADWAY AVE.  
MARYVILLE, TN 37804  
(865) 977-1200 FAX (865) 984-8616  
http://www.microbac.com  
E-Mail: knoxville@microbac.com

STATE CERT ID.  
TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS  
WATER · AIR · WASTES · FOOD · PHARMAUTICALS · NUTRACEUTICALCES

**CERTIFICATE OF ANALYSIS**

CITY OF KINGSTON  
CHUCK MOORE  
125 W. CUMBERLAND ST.  
KINGSTON, TN 37763

Date Reported 1/5/2010  
Date Received 12/23/2009  
Cust P.O.  
Invoice No. 77098  
Cust # C120  
Sample Date 12/23/2009  
Permit No. 0000360

Work Order Number: 0912-01048

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
------	--------	--------	------	------	------	------

RESPECTFULLY SUBMITTED: \_\_\_\_\_  
MICROBAC LABORATORIES, INC.

*Thank you for your business. We invite your feedback on our level of service to you. Please contact the Laboratory Director, James Nokes, at 865-977-1200, the COO, Robert Morgan, at rmorgan@microbac.com or the President, James Nokes, at jnokes@microbac.com with any comments or suggestions.*





# Microbac Laboratories, Inc.

KNOXVILLE DIVISION  
505 EAST BROADWAY AVE.  
MARYVILLE, TN 37804  
(865) 977-1200 FAX (865) 984-8616  
http://www.microbac.com  
E-Mail: knoxville@microbac.com

STATE CERT ID.  
TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS  
WATER · AIR · WASTES · FOOD · PHARMAUTICALS · NUTRACEUTICALCES

## CERTIFICATE OF ANALYSIS

CITY OF KINGSTON  
CHUCK MOORE  
125 W. CUMBERLAND ST.  
KINGSTON, TN 37763

Date Reported 1/5/2010  
Date Received 12/23/2009  
Cust P.O.  
Invoice No. 77098  
Cust # C120  
Sample Date 12/23/2009  
Permit No. 0000360

Work Order Number: 0912-01048

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
------	--------	--------	------	------	------	------

As regulatory limits change frequently, Microbac advises the recipient of this report to confirm such limits with the appropriate Federal, state, or local authorities before acting in reliance on the regulatory limits provided.

Microbac Laboratories, Inc. cannot guarantee the confidentiality of any facsimile or e-mail transmittal. The information in this communication is intended for the exclusive use of the addressee. If you are not the intended recipient, you are notified that any disclosure, copying, distributing, or the taking of any action in reliance on the contents of this information is strictly prohibited. If you received this transmission in error, please notify us immediately.

### QUALIFIER DEFINITIONS:

- B = Detected in the associated Method Blank
- C = As Tons CaCO<sub>3</sub>, equivalent per 1,000 tons material
- D = Surrogate recoveries not calculated due to matrix interference and resulting sample dilution
- E1 = Elevated detection limits due to sample matrix interference
- E2 = Elevated detection limits due to high analyte concentration
- H = Analyte was prepared and/or analyzed outside of the analytical method holding time
- I = Spike recovery outside control limits due to sample matrix interference or high analyte concentration
- J = The result is an estimated quantity. The associated numerical value is the approximate concentration of the analyte in the sample
- J+ = The result is an estimated quantity, but the result may be biased high
- J- = The result is an estimated quantity, but the result may be biased low
- UJ = The analyte was analyzed for, but was not detected. The reported quantitation limit is approximate and may be inaccurate or imprecise
- K = Inter-element correction applied due to high concentration of non-target analyte
- L1 = Liquid portion of dual phase sample analyzed only
- L2 = Solid portion of dual phase sample analyzed only
- M = Miscellaneous (see entry below analytical results)
- N = Analyte acceptable but matrix spike/matrix spike duplicate outside accepted recovery criteria
- \* = Matrix Spike/Matrix Spike Duplicate RPD is outside acceptable limits
- P = Sample received improperly preserved
- R = Relative Percent Duplicate (RPD) outside accepted recovery limits
- S1 = Spike recovery outside recovery limits
- S2 = Surrogate recovery outside of control limits. The data was accepted based on the valid recovery of remaining surrogate.
- U = Undetected
- V = Elevated reporting limits due to insufficient sample volume
- W = Results reports on dry weight basis
- Z = The parameter is considered a field analysis with an immediate to 15 minute holding time. Laboratory analysis is confirmatory in nature and is performed outside the preferred holding time window.

### ABBREVIATIONS:

- TNTC = Too Numerous To Count
- MG/KG = Milligrams per Kilogram (PPM)
- UG/L = Micrograms per Liter (PPB)
- CFU = Colony Forming Unit

