

Microbac

KNOXVILLE DIVISION
 505 EAST BROADWAY AVE.
 MARYVILLE, TN 37804
 (865) 977-1200 FAX (865) 984-8616
 http://www.microbac.com
 E-Mail: knoxville@microbac.com

STATE CERT ID.
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS
PRELIMINARY REPORT

CITY OF KINGSTON
 CHUCK MOORE
 125 W. CUMBERLAND ST.
 KINGSTON, TN 37763

Date Reported
 Date Received 1/19/2010
 Cust P.O.
 Invoice No.
 Cust # C120
 Sample Date 1/19/2010
 Permit No. 0000360

Work Order Number: 1001-00553

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
001 RAW 1/19/10 0630						
[TAL METALS]						
ALUMINUM	EPA 200.7	0.315 MG/L	J+	01/22/2010	12:06	SRR
ANTIMONY	EPA 200.7	<0.0020 MG/L	M	01/21/2010	15:26	SRR
ARSENIC	EPA 200.7	0.0011 MG/L	M	01/21/2010	15:26	SRR
BARIUM	EPA 200.7	0.0238 MG/L		01/21/2010	15:26	SRR
BERYLLIUM	EPA 200.7	<0.0010 MG/L		01/21/2010	15:26	SRR
CADMIUM	EPA 200.7	<0.0010 MG/L		01/21/2010	15:26	SRR
CHROMIUM	EPA 200.7	<0.0010 MG/L		01/21/2010	15:26	SRR
COBALT	EPA 200.7	<0.0010 MG/L		01/21/2010	15:26	SRR
COPPER	EPA 200.7	0.0083 MG/L		01/21/2010	15:26	SRR
IRON	EPA 200.7	0.281 MG/L		01/21/2010	15:26	SRR
LEAD	EPA 200.7	0.0021 MG/L	M	01/21/2010	15:26	SRR
MAGNESIUM	EPA 200.7	4.68 MG/L		01/20/2010	11:04	SRR
MANGANESE	EPA 200.7	0.0653 MG/L		01/21/2010	15:26	SRR
MOLYBDENUM	EPA 200.7	<0.0010 MG/L		01/21/2010	15:26	SRR
MERCURY	EPA 245.1	<0.0002 MG/L		01/19/2010	17:24	SRR
NICKEL	EPA 200.7	<0.0010 MG/L		01/21/2010	15:26	SRR
SELENIUM	EPA 200.7	<0.0020 MG/L	M	01/21/2010	15:26	SRR
SILVER	EPA 200.7	<0.0010 MG/L		01/21/2010	15:26	SRR
TIN	EPA 200.7	<0.0010 MG/L		01/21/2010	15:26	SRR
TITANIUM	EPA 200.7	0.0048 MG/L		01/21/2010	15:26	SRR
THALLIUM	EPA 200.7	<0.0020 MG/L	M	01/21/2010	15:26	SRR
ZINC	EPA 200.7	0.0589 MG/L		01/21/2010	15:26	SRR
BORON	EPA 200.7	0.0095 MG/L		01/21/2010	15:26	SRR
SOLIDS, TOTAL SUSPENDED	SM 2540.D.	10.1 MG/L		01/19/2010	09:00	KDW
HARDNESS, TOTAL AS CaCO3	EPA 200.7;2340.B.	63.1 MG/L	J+	01/20/2010	11:04	SRR



KNOXVILLE DIVISION
 505 EAST BROADWAY AVE.
 MARYVILLE, TN 37804
 (865) 977-1200 FAX (865) 984-8616
 http://www.microbac.com
 E-Mail: knoxville@microbac.com

STATE CERT ID.
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

PRELIMINARY REPORT

CERTIFICATE OF ANALYSIS

CITY OF KINGSTON
 CHUCK MOORE
 125 W. CUMBERLAND ST.
 KINGSTON, TN 37763

Date Reported
 Date Received 1/19/2010
 Cust P.O.
 Invoice No.
 Cust # C120
 Sample Date 1/19/2010
 Permit No. 0000360

Work Order Number: 1001-00553

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
------	--------	--------	------	------	------	------

002 RAW 1/19/10 0630 DISSOLVED METALS

Test	Method	Result	Qual	Date	Time	Tech
[TAL METALS]					00:00	
ALUMINUM	EPA 200.7	0.0477 MG/L		01/22/2010	12:34	SRR
ANTIMONY	EPA 200.7	<0.0020 MG/L	M	01/21/2010	15:40	SRR
ARSENIC	EPA 200.7	<0.0010 MG/L	M	01/21/2010	15:40	SRR
BARIUM	EPA 200.7	0.0183 MG/L		01/21/2010	15:40	SRR
BERYLLIUM	EPA 200.7	<0.0010 MG/L		01/21/2010	15:40	SRR
CADMIUM	EPA 200.7	<0.0010 MG/L		01/21/2010	15:40	SRR
CHROMIUM	EPA 200.7	<0.0010 MG/L		01/21/2010	15:40	SRR
COBALT	EPA 200.7	<0.0010 MG/L		01/21/2010	15:40	SRR
COPPER	EPA 200.7	0.0084 MG/L		01/21/2010	15:40	SRR
IRON	EPA 200.7	0.0141 MG/L		01/21/2010	15:40	SRR
LEAD	EPA 200.7	<0.0010 MG/L	M	01/21/2010	15:40	SRR
MAGNESIUM	EPA 200.7	0.862 MG/L		01/20/2010	14:15	SRR
MANGANESE	EPA 200.7	<0.0050 MG/L		01/21/2010	15:40	SRR
MOLYBDENUM	EPA 200.7	<0.0010 MG/L		01/21/2010	15:40	SRR
MERCURY	EPA 245.1	<0.0002 MG/L		01/19/2010	17:57	SRR
NICKEL	EPA 200.7	<0.0010 MG/L		01/21/2010	15:40	SRR
SELENIUM	EPA 200.7	<0.0020 MG/L	M	01/21/2010	15:40	SRR
SILVER	EPA 200.7	<0.0010 MG/L		01/21/2010	15:40	SRR
TIN	EPA 200.7	<0.0010 MG/L		01/21/2010	15:40	SRR
TITANIUM	EPA 200.7	<0.0010 MG/L		01/21/2010	15:40	SRR
THALLIUM	EPA 200.7	<0.0020 MG/L	M	01/21/2010	15:40	SRR
ZINC	EPA 200.7	0.0489 MG/L		01/21/2010	15:40	SRR
BORON	EPA 200.7	0.0094 MG/L		01/21/2010	15:40	SRR
SILICA (SiO2)	EPA 200.7	5.94 MG/L		01/20/2010	14:15	SRR



Microbac

KNOXVILLE DIVISION
 505 EAST BROADWAY AVE.
 MARYVILLE, TN 37804
 (865) 977-1200 FAX (865) 984-8616
 http://www.microbac.com
 E-Mail: knoxville@microbac.com

STATE CERT ID.
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS
PRELIMINARY REPORT

CITY OF KINGSTON
 CHUCK MOORE
 125 W. CUMBERLAND ST.
 KINGSTON, TN 37763

Date Reported
 Date Received 1/19/2010
 Cust P.O.
 Invoice No.
 Cust # C120
 Sample Date 1/19/2010
 Permit No. 0000360

Work Order Number: 1001-00553

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
------	--------	--------	------	------	------	------

003 **FINISHED 1/19/10 0630**

Test	Method	Result	Qual	Date	Time	Tech
[TAL METALS]					00:00	
ALUMINUM	EPA 200.7	0.0535 MG/L	J+	01/22/2010	12:13	SRR
ANTIMONY	EPA 200.7	<0.0020 MG/L	M	01/21/2010	15:33	SRR
ARSENIC	EPA 200.7	<0.0010 MG/L	M	01/21/2010	15:33	SRR
BARIUM	EPA 200.7	0.0174 MG/L		01/21/2010	15:33	SRR
BERYLLIUM	EPA 200.7	<0.0010 MG/L		01/21/2010	15:33	SRR
CADMIUM	EPA 200.7	<0.0010 MG/L		01/21/2010	15:33	SRR
CHROMIUM	EPA 200.7	<0.0010 MG/L		01/21/2010	15:33	SRR
COBALT	EPA 200.7	<0.0010 MG/L		01/21/2010	15:33	SRR
COPPER	EPA 200.7	0.0056 MG/L		01/21/2010	15:33	SRR
IRON	EPA 200.7	<0.0060 MG/L		01/21/2010	15:33	SRR
LEAD	EPA 200.7	<0.0010 MG/L	M	01/21/2010	15:33	SRR
MAGNESIUM	EPA 200.7	4.38 MG/L		01/20/2010	11:53	SRR
MANGANESE	EPA 200.7	<0.0050 MG/L		01/21/2010	15:33	SRR
MOLYBDENUM	EPA 200.7	<0.0010 MG/L		01/21/2010	15:33	SRR
MERCURY	EPA 245.1	<0.0002 MG/L		01/19/2010	17:53	SRR
NICKEL	EPA 200.7	0.0012 MG/L		01/21/2010	15:33	SRR
SELENIUM	EPA 200.7	<0.0020 MG/L	M	01/21/2010	15:33	SRR
SILVER	EPA 200.7	<0.0010 MG/L		01/21/2010	15:33	SRR
TIN	EPA 200.7	<0.0010 MG/L		01/21/2010	15:33	SRR
TITANIUM	EPA 200.7	<0.0010 MG/L		01/21/2010	15:33	SRR
THALLIUM	EPA 200.7	<0.0020 MG/L	M	01/21/2010	15:33	SRR
ZINC	EPA 200.7	0.0104 MG/L		01/21/2010	15:33	SRR
BORON	EPA 200.7	0.0085 MG/L		01/21/2010	15:33	SRR
SOLIDS, TOTAL SUSPENDED	SM 2540,D.	<4.00 MG/L		01/19/2010	09:00	KDW

Microbac

KNOXVILLE DIVISION
 505 EAST BROADWAY AVE.
 MARYVILLE, TN 37804
 (865) 977-1200 FAX (865) 984-8616
 http://www.microbac.com
 E-Mail: knoxville@microbac.com

STATE CERT ID.
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS
PRELIMINARY REPORT

CITY OF KINGSTON
 CHUCK MOORE
 125 W. CUMBERLAND ST.
 KINGSTON, TN 37763

Date Reported
 Date Received 1/19/2010
 Cust P.O.
 Invoice No.
 Cust # C120
 Sample Date 1/19/2010
 Permit No. 0000360

Work Order Number: 1001-00553

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
003 FINISHED 1/19/10 0630						
.....continued						
HARDNESS, TOTAL AS CaCO3	EPA 200.7;2340,B.	59.5 MG/L	J+	01/20/2010	11:53	SRR
004 FINISHED 1/19/10 0630 DISSOLVED METALS						
[TAL METALS]					00:00	
ALUMINUM	EPA 200.7	0.0475 MG/L		01/22/2010	12:41	SRR
ANTIMONY	EPA 200.7	<0.0020 MG/L	M	01/21/2010	15:47	SRR
ARSENIC	EPA 200.7	<0.0010 MG/L	M	01/21/2010	15:47	SRR
BARIUM	EPA 200.7	0.0167 MG/L		01/21/2010	15:47	SRR
BERYLLIUM	EPA 200.7	<0.0010 MG/L		01/21/2010	15:47	SRR
CADMIUM	EPA 200.7	<0.0010 MG/L		01/21/2010	15:47	SRR
CHROMIUM	EPA 200.7	<0.0010 MG/L		01/21/2010	15:47	SRR
COBALT	EPA 200.7	<0.0010 MG/L		01/21/2010	15:47	SRR
COPPER	EPA 200.7	0.0066 MG/L		01/21/2010	15:47	SRR
IRON	EPA 200.7	<0.0060 MG/L		01/21/2010	15:47	SRR
LEAD	EPA 200.7	<0.0010 MG/L	M	01/21/2010	15:47	SRR
MAGNESIUM	EPA 200.7	4.27 MG/L		01/20/2010	14:34	SRR
MANGANESE	EPA 200.7	<0.0050 MG/L		01/21/2010	15:47	SRR
MOLYBDENUM	EPA 200.7	<0.0010 MG/L		01/21/2010	15:47	SRR
MERCURY	EPA 245.1	<0.0002 MG/L		01/19/2010	18:01	SRR
NICKEL	EPA 200.7	<0.0010 MG/L		01/21/2010	15:47	SRR
SELENIUM	EPA 200.7	<0.0020 MG/L	M	01/21/2010	15:47	SRR
SILVER	EPA 200.7	<0.0010 MG/L		01/21/2010	15:47	SRR
TIN	EPA 200.7	<0.0010 MG/L		01/21/2010	15:47	SRR
TITANIUM	EPA 200.7	<0.0010 MG/L		01/21/2010	15:47	SRR

® **Microbac Laboratories, Inc.**



KNOXVILLE DIVISION
 505 EAST BROADWAY AVE.
 MARYVILLE, TN 37804
 (865) 977-1200 FAX (865) 984-8616
 http://www.microbac.com
 E-Mail: knoxville@microbac.com

STATE CERT ID.
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

PRELIMINARY REPORT

CERTIFICATE OF ANALYSIS

CITY OF KINGSTON
 CHUCK MOORE
 125 W. CUMBERLAND ST.
 KINGSTON, TN 37763

Date Reported
 Date Received 1/19/2010
 Cust P.O.
 Invoice No.
 Cust # C120
 Sample Date 1/19/2010
 Permit No. 0000360

Work Order Number: 1001-00553

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
------	--------	--------	------	------	------	------

004 **FINISHED 1/19/10 0630 DISSOLVED METALS**

.....continued

THALLIUM	EPA 200.7	<0.0020 MG/L	M	01/21/2010	15:47	SRR
ZINC	EPA 200.7	0.0103 MG/L		01/21/2010	15:47	SRR
BORON	EPA 200.7	0.0118 MG/L		01/21/2010	15:47	SRR
SILICA (SiO2)	EPA 200.7	6.22 MG/L		01/20/2010	14:34	SRR

M= THESE SAMPLES ARE REPORTED BY METHOD 200.7 FOR INFORMATIONAL PURPOSES TO PROVIDE QUICKER REPORTING. WHILE THESE REPORTED NUMBERS ARE CONSIDERED ACCURATE, TDEC APPROVED METHODS (EITHER 200.8 OR 200.9) ARE ALSO BEING ANALYZED AS VERIFICATION AND THIS REPORT WILL BE MODIFIED TO REFLECT THE METHOD CHANGE WHEN COMPLETE.

RESPECTFULLY SUBMITTED: _____

MICROBAC LABORATORIES, INC.

Thank you for your business. We invite your feedback on our level of service to you. Please contact the Laboratory Director, James Nokes, at 865-977-1200, the COO, Robert Morgan, at rmorgan@microbac.com or the President, James Nokes, at jnokes@microbac.com with any comments or suggestions.

® **Microbac Laboratories, Inc.**

Microbac

KNOXVILLE DIVISION
 505 EAST BROADWAY AVE.
 MARYVILLE, TN 37804
 (865) 977-1200 FAX (865) 984-8616
 http://www.microbac.com
 E-Mail: knoxville@microbac.com

STATE CERT ID.
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS
PRELIMINARY REPORT

CITY OF KINGSTON
 CHUCK MOORE
 125 W. CUMBERLAND ST.
 KINGSTON, TN 37763

Date Reported
 Date Received 1/19/2010
 Cust P.O.
 Invoice No.
 Cust # C120
 Sample Date 1/19/2010
 Permit No. 0000360

Work Order Number: 1001-00553

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
------	--------	--------	------	------	------	------

As regulatory limits change frequently, Microbac advises the recipient of this report to confirm such limits with the appropriate Federal, state, or local authorities before acting in reliance on the regulatory limits provided.

Microbac Laboratories, Inc. cannot guarantee the confidentiality of any facsimile or e-mail transmittal. The information in this communication is intended for the exclusive use of the addressee. If you are not the intended recipient, you are notified that any disclosure, copying, distributing, or the taking of any action in reliance on the contents of this information is strictly prohibited. If you received this transmission in error, please notify us immediately.

QUALIFIER DEFINITIONS:

- B = Detected in the associated Method Blank
- C = As Tons CaCO3, equivalent per 1,000 tons material
- D = Surrogate recoveries not calculated due to matrix interference and resulting sample dilution
- E1 = Elevated detection limits due to sample matrix interference
- E2 = Elevated detection limits due to high analyte concentration
- H = Analyte was prepared and/or analyzed outside of the analytical method holding time
- I = Spike recovery outside control limits due to sample matrix interference or high analyte concentration
- J = The result is an estimated quantity. The associated numerical value is the approximate concentration of the analyte in the sample
- J+ = The result is an estimated quantity, but the result may be biased high
- J- = The result is an estimated quantity, but the result may be biased low
- UJ = The analyte was analyzed for, but was not detected. The reported quantitation limit is approximate and may be inaccurate or imprecise
- K = Analyte concentration estimated due to sample matrix interference and/or high analyte concentration interference
- L1 = Liquid portion of dual phase sample analyzed only
- L2 = Solid portion of dual phase sample analyzed only
- M = Miscellaneous (see entry below analytical results)
- N = Analyte acceptable but matrix spike/matrix spike duplicate outside accepted recovery criteria
- * = Matrix Spike/Matrix Spike Duplicate RPD is outside acceptable limits
- P = Sample received improperly preserved
- R = Relative Percent Duplicate (RPD) outside accepted recovery limits
- S1 = Spike recovery outside recovery limits
- S2 = Surrogate recovery outside of control limits. The data was accepted based on the valid recovery of remaining surrogate.
- U = Undetected
- V = Elevated reporting limits due to insufficient sample volume
- W = Results reports on dry weight basis
- Z - The parameter is considered a field analysis with an immediate to 15 minute holding time. Laboratory analysis is confirmatory in nature and is performed outside the preferred holding time window.

ABBREVIATIONS:

- TNTC = Too Numerous To Count
- MG/KG = Milligrams per Kilogram (PPM)
- UG/L = Micrograms per Liter (PPB)
- CFU = Colony Forming Unit



® **Microbac Laboratories, Inc.**

KNOXVILLE DIVISION
 505 EAST BROADWAY AVE.
 MARYVILLE, TN 37804
 (865) 977-1200 FAX (865) 984-8616
 http://www.microbac.com
 E-Mail: knoxville@microbac.com

STATE CERT ID.
 TN 02017



CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS
PRELIMINARY REPORT

CITY OF KINGSTON
 CHUCK MOORE
 125 W. CUMBERLAND ST.
 KINGSTON, TN 37763

Date Reported
 Date Received 1/19/2010
 Cust P.O.
 Invoice No.
 Cust # C120
 Sample Date 1/19/2010
 Permit No. 0000360

Work Order Number: 1001-00553

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
------	--------	--------	------	------	------	------

