

Microbac

KNOXVILLE DIVISION
 505 EAST BROADWAY AVE.
 MARYVILLE, TN 37804
 (865) 977-1200 FAX (865) 984-8616
 http://www.microbac.com
 E-Mail: knoxville@microbac.com

STATE CERT ID.
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS
PRELIMINARY REPORT

CITY OF KINGSTON
 CHUCK MOORE
 125 W. CUMBERLAND ST.
 KINGSTON, TN 37763

Date Reported
 Date Received 2/17/2010
 Cust P.O.
 Invoice No.
 Cust # C120
 Sample Date 2/17/2010
 Permit No. 0000360

Work Order Number: 1002-00635

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
001 RAW 2/17/10 0630						
[TAL METALS]				02/18/2010	16:49	SRR
ALUMINUM	EPA 200.7	0.347 MG/L	J+, B	02/19/2010	11:35	SRR
ANTIMONY	EPA 200.8	<0.005 MG/L		02/18/2010	16:49	MTC
ARSENIC	EPA 200.8	<0.005 MG/L		02/18/2010	16:49	MTC
BARIUM	EPA 200.7	0.0211 MG/L		02/19/2010	11:35	SRR
BERYLLIUM	EPA 200.7	<0.0010 MG/L		02/19/2010	11:35	SRR
CADMIUM	EPA 200.7	<0.0010 MG/L		02/19/2010	11:35	SRR
CHROMIUM	EPA 200.7	<0.0010 MG/L		02/19/2010	11:35	SRR
COBALT	EPA 200.7	<0.0010 MG/L		02/19/2010	11:35	SRR
COPPER	EPA 200.7	0.0021 MG/L		02/19/2010	11:35	SRR
IRON	EPA 200.7	0.318 MG/L		02/19/2010	11:35	SRR
LEAD	EPA 200.8	<0.005 MG/L		02/18/2010	16:49	MTC
MAGNESIUM	EPA 200.7	4.15 MG/L	B	02/19/2010	11:35	SRR
MANGANESE	EPA 200.7	0.0259 MG/L		02/19/2010	11:35	SRR
MOLYBDENUM	EPA 200.7	<0.0010 MG/L		02/19/2010	11:35	SRR
MERCURY	EPA 245.1	<0.0002 MG/L		02/22/2010	13:12	SRR
NICKEL	EPA 200.7	<0.0010 MG/L		02/19/2010	11:35	SRR
SELENIUM	EPA 200.8	<0.005 MG/L		02/18/2010	16:49	MTC
SILVER	EPA 200.7	<0.0010 MG/L		02/19/2010	11:35	SRR
TIN	EPA 200.7	<0.0010 MG/L		02/19/2010	11:35	SRR
TITANIUM	EPA 200.7	0.0122 MG/L	N	02/19/2010	11:35	SRR
THALLIUM	EPA 200.8	<0.001 MG/L		02/18/2010	16:49	MTC
ZINC	EPA 200.7	0.0196 MG/L	N, B	02/19/2010	11:35	SRR
BORON	EPA 200.7	0.0070 MG/L		02/19/2010	11:35	SRR
SOLIDS, TOTAL SUSPENDED	SM 2540.D.	4.84 MG/L		02/17/2010	12:00	KDW
HARDNESS, TOTAL AS CaCO3	EPA 200.7;2340.B.	59.1 MG/L	J+	02/19/2010	11:35	SRR

Microbac

KNOXVILLE DIVISION
 505 EAST BROADWAY AVE.
 MARYVILLE, TN 37804
 (865) 977-1200 FAX (865) 984-8616
 http://www.microbac.com
 E-Mail: knoxville@microbac.com

STATE CERT ID.
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS
PRELIMINARY REPORT

CITY OF KINGSTON
 CHUCK MOORE
 125 W. CUMBERLAND ST.
 KINGSTON, TN 37763

Date Reported
 Date Received 2/17/2010
 Cust P.O.
 Invoice No.
 Cust # C120
 Sample Date 2/17/2010
 Permit No. 0000360

Work Order Number: 1002-00635

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
------	--------	--------	------	------	------	------

002 **RAW 2/17/10 0630 DISSOLVED METALS**

Test	Method	Result	Qual	Date	Time	Tech
[TAL METALS]					00:00	
ALUMINUM	EPA 200.7	<0.0050 MG/L	J+, B	02/19/2010	12:55	SRR
ANTIMONY	EPA 200.8	<0.005 MG/L		02/18/2010	15:26	MTC
ARSENIC	EPA 200.8	<0.005 MG/L		02/18/2010	15:26	MTC
BARIUM	EPA 200.7	0.0196 MG/L		02/19/2010	12:55	SRR
BERYLLIUM	EPA 200.7	<0.0010 MG/L		02/19/2010	12:55	SRR
CADMIUM	EPA 200.7	<0.0010 MG/L		02/19/2010	12:55	SRR
CHROMIUM	EPA 200.7	<0.0010 MG/L		02/19/2010	12:55	SRR
COBALT	EPA 200.7	<0.0010 MG/L		02/19/2010	12:55	SRR
COPPER	EPA 200.7	0.0013 MG/L		02/19/2010	12:55	SRR
IRON	EPA 200.7	0.0367 MG/L	B	02/19/2010	12:55	SRR
LEAD	EPA 200.8	<0.005 MG/L		02/18/2010	15:26	MTC
MAGNESIUM	EPA 200.7	4.26 MG/L	B	02/19/2010	12:55	SRR
MANGANESE	EPA 200.7	0.0070 MG/L		02/19/2010	12:55	SRR
MOLYBDENUM	EPA 200.7	<0.0010 MG/L		02/19/2010	12:55	SRR
MERCURY	EPA 245.1	<0.0002 MG/L		02/19/2010	16:09	SRR
NICKEL	EPA 200.7	<0.0010 MG/L		02/19/2010	12:55	SRR
SELENIUM	EPA 200.8	<0.005 MG/L		02/18/2010	15:26	MTC
SILVER	EPA 200.7	<0.0010 MG/L		02/19/2010	12:55	SRR
TIN	EPA 200.7	<0.0010 MG/L		02/19/2010	12:55	SRR
TITANIUM	EPA 200.7	<0.0010 MG/L		02/19/2010	12:55	SRR
THALLIUM	EPA 200.8	<0.001 MG/L		02/18/2010	15:26	MTC
ZINC	EPA 200.7	0.0170 MG/L	B	02/19/2010	12:55	SRR
BORON	EPA 200.7	0.0068 MG/L		02/19/2010	12:55	SRR
SILICA (SiO2)	EPA 200.7	5.67 MG/L		02/19/2010	12:55	SRR

Microbac

KNOXVILLE DIVISION
 505 EAST BROADWAY AVE.
 MARYVILLE, TN 37804
 (865) 977-1200 FAX (865) 984-8616
 http://www.microbac.com
 E-Mail: knoxville@microbac.com

STATE CERT ID.
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS
PRELIMINARY REPORT

CITY OF KINGSTON
 CHUCK MOORE
 125 W. CUMBERLAND ST.
 KINGSTON, TN 37763

Date Reported
 Date Received 2/17/2010
 Cust P.O.
 Invoice No.
 Cust # C120
 Sample Date 2/17/2010
 Permit No. 0000360

Work Order Number: 1002-00635

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
------	--------	--------	------	------	------	------

003 **FINISHED 2/17/10 0630**

Test	Method	Result	Qual	Date	Time	Tech
[TAL METALS]					00:00	
ALUMINUM	EPA 200.7	0.0194 MG/L	J+, B	02/19/2010	12:11	SRR
ANTIMONY	EPA 200.8	<0.005 MG/L		02/18/2010	15:26	MTC
ARSENIC	EPA 200.8	<0.005 MG/L		02/18/2010	15:26	MTC
BARIUM	EPA 200.7	0.0191 MG/L		02/19/2010	12:11	SRR
BERYLLIUM	EPA 200.7	<0.0010 MG/L		02/19/2010	12:11	SRR
CADMIUM	EPA 200.7	<0.0010 MG/L		02/19/2010	12:11	SRR
CHROMIUM	EPA 200.7	<0.0010 MG/L		02/19/2010	12:11	SRR
COBALT	EPA 200.7	<0.0010 MG/L		02/19/2010	12:11	SRR
COPPER	EPA 200.7	0.0039 MG/L		02/19/2010	12:11	SRR
IRON	EPA 200.7	<0.0060 MG/L		02/19/2010	12:11	SRR
LEAD	EPA 200.8	<0.005 MG/L		02/18/2010	15:26	MTC
MAGNESIUM	EPA 200.7	4.37 MG/L	B	02/19/2010	12:11	SRR
MANGANESE	EPA 200.7	<0.0050 MG/L		02/19/2010	12:11	SRR
MOLYBDENUM	EPA 200.7	<0.0010 MG/L		02/19/2010	12:11	SRR
MERCURY	EPA 245.1	<0.0002 MG/L		02/22/2010	13:12	SRR
NICKEL	EPA 200.7	<0.0010 MG/L		02/19/2010	12:11	SRR
SELENIUM	EPA 200.8	<0.005 MG/L		02/18/2010	15:26	MTC
SILVER	EPA 200.7	<0.0010 MG/L		02/19/2010	12:11	SRR
TIN	EPA 200.7	<0.0010 MG/L		02/19/2010	12:11	SRR
TITANIUM	EPA 200.7	<0.0010 MG/L	N	02/19/2010	12:11	SRR
THALLIUM	EPA 200.8	<0.001 MG/L		02/18/2010	15:26	MTC
ZINC	EPA 200.7	0.0239 MG/L	N, B	02/19/2010	12:11	SRR
BORON	EPA 200.7	0.0068 MG/L		02/19/2010	12:11	SRR
SOLIDS, TOTAL SUSPENDED	SM 2540,D.	<4.00 MG/L		02/17/2010	12:00	KDW

Microbac

KNOXVILLE DIVISION
 505 EAST BROADWAY AVE.
 MARYVILLE, TN 37804
 (865) 977-1200 FAX (865) 984-8616
 http://www.microbac.com
 E-Mail: knoxville@microbac.com

STATE CERT ID.
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS
PRELIMINARY REPORT

CITY OF KINGSTON
 CHUCK MOORE
 125 W. CUMBERLAND ST.
 KINGSTON, TN 37763

Date Reported
 Date Received 2/17/2010
 Cust P.O.
 Invoice No.
 Cust # C120
 Sample Date 2/17/2010
 Permit No. 0000360

Work Order Number: 1002-00635

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
003 FINISHED 2/17/10 0630						
.....continued						
HARDNESS, TOTAL AS CaCO3	EPA 200.7;2340,B.	63.1 MG/L	J+	02/19/2010	12:11	SRR
004 FINISHED 2/17/10 0630 DISSOLVED METALS						
[TAL METALS]					00:00	
ALUMINUM	EPA 200.7	0.0069 MG/L	J+, B	02/19/2010	13:03	SRR
ANTIMONY	EPA 200.8	<0.005 MG/L		02/18/2010	15:26	MTC
ARSENIC	EPA 200.8	<0.005 MG/L		02/18/2010	15:26	MTC
BARIUM	EPA 200.7	0.0182 MG/L		02/19/2010	13:03	SRR
BERYLLIUM	EPA 200.7	<0.0010 MG/L		02/19/2010	13:03	SRR
CADMIUM	EPA 200.7	<0.0010 MG/L		02/19/2010	13:03	SRR
CHROMIUM	EPA 200.7	<0.0010 MG/L		02/19/2010	13:03	SRR
COBALT	EPA 200.7	<0.0010 MG/L		02/19/2010	13:03	SRR
COPPER	EPA 200.7	0.0034 MG/L		02/19/2010	13:03	SRR
IRON	EPA 200.7	<0.0060 MG/L	B	02/19/2010	13:03	SRR
LEAD	EPA 200.8	<0.005 MG/L		02/18/2010	15:26	MTC
MAGNESIUM	EPA 200.7	4.19 MG/L	B	02/19/2010	13:03	SRR
MANGANESE	EPA 200.7	<0.0050 MG/L		02/19/2010	13:03	SRR
MOLYBDENUM	EPA 200.7	<0.0010 MG/L		02/19/2010	13:03	SRR
MERCURY	EPA 245.1	<0.0002 MG/L		02/19/2010	16:09	SRR
NICKEL	EPA 200.7	<0.0010 MG/L		02/19/2010	13:03	SRR
SELENIUM	EPA 200.8	<0.005 MG/L		02/18/2010	15:26	MTC
SILVER	EPA 200.7	<0.0010 MG/L		02/19/2010	13:03	SRR
TIN	EPA 200.7	<0.0010 MG/L		02/19/2010	13:03	SRR
TITANIUM	EPA 200.7	<0.0010 MG/L		02/19/2010	13:03	SRR

® **Microbac Laboratories, Inc.**



KNOXVILLE DIVISION
 505 EAST BROADWAY AVE.
 MARYVILLE, TN 37804
 (865) 977-1200 FAX (865) 984-8616
 http://www.microbac.com
 E-Mail: knoxville@microbac.com

STATE CERT ID.

TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS
PRELIMINARY REPORT

CITY OF KINGSTON
 CHUCK MOORE
 125 W. CUMBERLAND ST.
 KINGSTON, TN 37763

Date Reported
 Date Received 2/17/2010
 Cust P.O.
 Invoice No.
 Cust # C120
 Sample Date 2/17/2010
 Permit No. 0000360

Work Order Number: 1002-00635

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
------	--------	--------	------	------	------	------

004 **FINISHED 2/17/10 0630 DISSOLVED METALS**

.....continued

THALLIUM	EPA 200.8	<0.001 MG/L		02/18/2010	15:26	MTC
ZINC	EPA 200.7	0.0043 MG/L	B	02/19/2010	13:03	SRR
BORON	EPA 200.7	0.0068 MG/L		02/19/2010	13:03	SRR
SILICA (SiO2)	EPA 200.7	5.87 MG/L		02/19/2010	13:03	SRR

REVISED REPORT TO CONTAIN BACK-UP STATE CERTIFIED DATA FOR SB, AS, PB, SE AND TL. ANALYSIS SUBCONTRACTED TO MICROBAC LABORATORIES TRI-CITIES DIVISION (TN LAB ID#04017). LL 02-22-10.

RESPECTFULLY SUBMITTED: _____

MICROBAC LABORATORIES, INC.

Thank you for your business. We invite your feedback on our level of service to you. Please contact the Laboratory Director, James Nokes, at 865-977-1200, the COO, Robert Morgan, at rmorgan@microbac.com or the President, James Nokes, at jnokes@microbac.com with any comments or suggestions.

Microbac

KNOXVILLE DIVISION
 505 EAST BROADWAY AVE.
 MARYVILLE, TN 37804
 (865) 977-1200 FAX (865) 984-8616
 http://www.microbac.com
 E-Mail: knoxville@microbac.com

STATE CERT ID.

TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS
PRELIMINARY REPORT

CITY OF KINGSTON
 CHUCK MOORE
 125 W. CUMBERLAND ST.
 KINGSTON, TN 37763

Date Reported
 Date Received 2/17/2010
 Cust P.O.
 Invoice No.
 Cust # C120
 Sample Date 2/17/2010
 Permit No. 0000360

Work Order Number: 1002-00635

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
------	--------	--------	------	------	------	------

As regulatory limits change frequently, Microbac advises the recipient of this report to confirm such limits with the appropriate Federal, state, or local authorities before acting in reliance on the regulatory limits provided.

Microbac Laboratories, Inc. cannot guarantee the confidentiality of any facsimile or e-mail transmittal. The information in this communication is intended for the exclusive use of the addressee. If you are not the intended recipient, you are notified that any disclosure, copying, distributing, or the taking of any action in reliance on the contents of this information is strictly prohibited. If you received this transmission in error, please notify us immediately.

QUALIFIER DEFINITIONS:

- B = Detected in the associated Method Blank
- C = As Tons CaCO₃, equivalent per 1,000 tons material
- D = Surrogate recoveries not calculated due to matrix interference and resulting sample dilution
- E1 = Elevated detection limits due to sample matrix interference
- E2 = Elevated detection limits due to high analyte concentration
- H = Analyte was prepared and/or analyzed outside of the analytical method holding time
- I = Spike recovery outside control limits due to sample matrix interference or high analyte concentration
- J = The result is an estimated quantity. The associated numerical value is the approximate concentration of the analyte in the sample
- J+ = The result is an estimated quantity, but the result may be biased high
- J- = The result is an estimated quantity, but the result may be biased low
- UJ = The analyte was analyzed for, but was not detected. The reported quantitation limit is approximate and may be inaccurate or imprecise
- K = Analyte concentration estimated due to sample matrix interference and/or high analyte concentration interference
- L1 = Liquid portion of dual phase sample analyzed only
- L2 = Solid portion of dual phase sample analyzed only
- M = Miscellaneous (see entry below analytical results)
- N = Analyte acceptable but matrix spike/matrix spike duplicate outside accepted recovery criteria
- * = Matrix Spike/Matrix Spike Duplicate RPD is outside acceptable limits
- P = Sample received improperly preserved
- R = Relative Percent Duplicate (RPD) outside accepted recovery limits
- S1 = Spike recovery outside recovery limits
- S2 = Surrogate recovery outside of control limits. The data was accepted based on the valid recovery of remaining surrogate.
- U = Undetected
- V = Elevated reporting limits due to insufficient sample volume
- W = Results reports on dry weight basis
- Z - The parameter is considered a field analysis with an immediate to 15 minute holding time. Laboratory analysis is confirmatory in nature and is performed outside the preferred holding time window.

ABBREVIATIONS:

- TNTC = Too Numerous To Count
- MG/KG = Milligrams per Kilogram (PPM)
- UG/L = Micrograms per Liter (PPB)
- CFU = Colony Forming Unit



® **Microbac Laboratories, Inc.**

Microbac

KNOXVILLE DIVISION
 505 EAST BROADWAY AVE.
 MARYVILLE, TN 37804
 (865) 977-1200 FAX (865) 984-8616
 http://www.microbac.com
 E-Mail: knoxville@microbac.com

STATE CERT ID.
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

CERTIFICATE OF ANALYSIS
PRELIMINARY REPORT

CITY OF KINGSTON
 CHUCK MOORE
 125 W. CUMBERLAND ST.
 KINGSTON, TN 37763

Date Reported
 Date Received 2/17/2010
 Cust P.O.
 Invoice No.
 Cust # C120
 Sample Date 2/17/2010
 Permit No. 0000360

Work Order Number: 1002-00635

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
------	--------	--------	------	------	------	------