

**Microbac**

KNOXVILLE DIVISION  
 505 EAST BROADWAY AVE.  
 MARYVILLE, TN 37804  
 (865) 977-1200 FAX (865) 984-8616  
 http://www.microbac.com  
 E-Mail: knoxville@microbac.com

STATE CERT ID.  
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS  
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

**CERTIFICATE OF ANALYSIS**  
**PRELIMINARY REPORT**

CITY OF KINGSTON  
 CHUCK MOORE  
 125 W. CUMBERLAND ST.  
 KINGSTON, TN 37763

Date Reported  
 Date Received 3/6/2010  
 Cust P.O.  
 Invoice No.  
 Cust # C120  
 Sample Date 3/6/2010  
 Permit No. 0000360

Work Order Number: 1003-00149

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
<b>001 RAW 3/6/10 0630</b>						
[ TAL METALS ]						
ALUMINUM	EPA 200.7	0.175 MG/L	J+, N, B	03/09/2010	11:06	SRR
ANTIMONY	EPA 200.7	<0.0020 MG/L	M	03/09/2010	11:06	SRR
ARSENIC	EPA 200.7	<0.0010 MG/L	M	03/09/2010	11:06	SRR
BARIUM	EPA 200.7	0.0199 MG/L	N	03/09/2010	11:06	SRR
BERYLLIUM	EPA 200.7	<0.0010 MG/L		03/09/2010	11:06	SRR
CADMIUM	EPA 200.7	<0.0010 MG/L		03/09/2010	11:06	SRR
CHROMIUM	EPA 200.7	<0.0010 MG/L		03/09/2010	11:06	SRR
COBALT	EPA 200.7	<0.0010 MG/L		03/09/2010	11:06	SRR
COPPER	EPA 200.7	0.0019 MG/L		03/09/2010	11:06	SRR
IRON	EPA 200.7	0.217 MG/L	N	03/09/2010	11:06	SRR
LEAD	EPA 200.7	<0.0010 MG/L	M	03/09/2010	11:06	SRR
MAGNESIUM	EPA 200.7	3.99 MG/L	J-, *, N	03/09/2010	11:06	SRR
MANGANESE	EPA 200.7	0.0302 MG/L	N	03/09/2010	11:06	SRR
MOLYBDENUM	EPA 200.7	<0.0010 MG/L		03/09/2010	11:06	SRR
MERCURY	EPA 245.1	<0.0002 MG/L		03/08/2010	18:29	SRR
NICKEL	EPA 200.7	<0.0010 MG/L		03/09/2010	11:06	SRR
SELENIUM	EPA 200.7	<0.0020 MG/L	M	03/09/2010	11:06	SRR
SILVER	EPA 200.7	<0.0010 MG/L	J-, B	03/09/2010	11:06	SRR
TIN	EPA 200.7	<0.0010 MG/L	B	03/09/2010	11:06	SRR
TITANIUM	EPA 200.7	0.0038 MG/L		03/09/2010	11:06	SRR
THALLIUM	EPA 200.7	<0.0020 MG/L	M	03/09/2010	11:06	SRR
ZINC	EPA 200.7	0.0218 MG/L		03/09/2010	11:06	SRR
BORON	EPA 200.7	0.0085 MG/L		03/09/2010	11:06	SRR
SOLIDS, TOTAL SUSPENDED	SM 2540.D.	<4.00 MG/L		03/08/2010	09:45	KDW
HARDNESS, TOTAL AS CaCO3	EPA 200.7;2340.B.	59.6 MG/L	J-, *	03/09/2010	11:06	SRR

**Microbac**

KNOXVILLE DIVISION  
 505 EAST BROADWAY AVE.  
 MARYVILLE, TN 37804  
 (865) 977-1200 FAX (865) 984-8616  
 http://www.microbac.com  
 E-Mail: knoxville@microbac.com

STATE CERT ID.  
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS  
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

**CERTIFICATE OF ANALYSIS**  
**PRELIMINARY REPORT**

CITY OF KINGSTON  
 CHUCK MOORE  
 125 W. CUMBERLAND ST.  
 KINGSTON, TN 37763

Date Reported  
 Date Received 3/6/2010  
 Cust P.O.  
 Invoice No.  
 Cust # C120  
 Sample Date 3/6/2010  
 Permit No. 0000360

Work Order Number: 1003-00149

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
------	--------	--------	------	------	------	------

002 **RAW 3/6/10 0630 DISSOLVED METALS**

Test	Method	Result	Qual	Date	Time	Tech
[ TAL METALS ]					00:00	
ALUMINUM	EPA 200.7	0.0419 MG/L	J+, B	03/09/2010	11:21	SRR
ANTIMONY	EPA 200.7	<0.0020 MG/L	M	03/09/2010	11:21	SRR
ARSENIC	EPA 200.7	<0.0010 MG/L	M	03/09/2010	11:21	SRR
BARIUM	EPA 200.7	0.0183 MG/L	B	03/09/2010	11:21	SRR
BERYLLIUM	EPA 200.7	<0.0010 MG/L		03/09/2010	11:21	SRR
CADMIUM	EPA 200.7	<0.0010 MG/L		03/09/2010	11:21	SRR
CHROMIUM	EPA 200.7	<0.0010 MG/L		03/09/2010	11:21	SRR
COBALT	EPA 200.7	<0.0010 MG/L		03/09/2010	11:21	SRR
COPPER	EPA 200.7	0.0021 MG/L		03/09/2010	11:21	SRR
IRON	EPA 200.7	0.0227 MG/L		03/09/2010	11:21	SRR
LEAD	EPA 200.7	<0.0010 MG/L	M	03/09/2010	11:21	SRR
MAGNESIUM	EPA 200.7	3.89 MG/L	J-	03/09/2010	11:21	SRR
MANGANESE	EPA 200.7	0.0105 MG/L		03/09/2010	11:21	SRR
MOLYBDENUM	EPA 200.7	<0.0010 MG/L		03/09/2010	11:21	SRR
MERCURY	EPA 245.1	<0.0002 MG/L		03/09/2010	14:10	SRR
NICKEL	EPA 200.7	<0.0010 MG/L		03/09/2010	11:21	SRR
SELENIUM	EPA 200.7	<0.0020 MG/L	M	03/09/2010	11:21	SRR
SILVER	EPA 200.7	<0.0010 MG/L	J-	03/09/2010	11:21	SRR
TIN	EPA 200.7	<0.0010 MG/L	B	03/09/2010	11:21	SRR
TITANIUM	EPA 200.7	<0.0010 MG/L		03/09/2010	11:21	SRR
THALLIUM	EPA 200.7	<0.0020 MG/L	M	03/09/2010	11:21	SRR
ZINC	EPA 200.7	0.0112 MG/L		03/09/2010	11:21	SRR
BORON	EPA 200.7	0.0134 MG/L		03/09/2010	11:21	SRR
SILICA (SiO2)	EPA 200.7	5.73 MG/L		03/09/2010	11:21	SRR

**Microbac**

KNOXVILLE DIVISION  
 505 EAST BROADWAY AVE.  
 MARYVILLE, TN 37804  
 (865) 977-1200 FAX (865) 984-8616  
 http://www.microbac.com  
 E-Mail: knoxville@microbac.com

STATE CERT ID.  
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS  
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

**CERTIFICATE OF ANALYSIS**  
**PRELIMINARY REPORT**

CITY OF KINGSTON  
 CHUCK MOORE  
 125 W. CUMBERLAND ST.  
 KINGSTON, TN 37763

Date Reported  
 Date Received 3/6/2010  
 Cust P.O.  
 Invoice No.  
 Cust # C120  
 Sample Date 3/6/2010  
 Permit No. 0000360

Work Order Number: 1003-00149

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
------	--------	--------	------	------	------	------

003 **FINISHED 3/6/10 0630**

[ TAL METALS ]

Test	Method	Result	Qual	Date	Time	Tech
ALUMINUM	EPA 200.7	0.0463 MG/L	J+, N, B	03/09/2010	11:13	SRR
ANTIMONY	EPA 200.7	<0.0020 MG/L	M	03/09/2010	11:13	SRR
ARSENIC	EPA 200.7	<0.0010 MG/L	M	03/09/2010	11:13	SRR
BARIUM	EPA 200.7	0.0185 MG/L	N	03/09/2010	11:13	SRR
BERYLLIUM	EPA 200.7	<0.0010 MG/L		03/09/2010	11:13	SRR
CADMIUM	EPA 200.7	<0.0010 MG/L		03/09/2010	11:13	SRR
CHROMIUM	EPA 200.7	<0.0010 MG/L		03/09/2010	11:13	SRR
COBALT	EPA 200.7	<0.0010 MG/L		03/09/2010	11:13	SRR
COPPER	EPA 200.7	0.0026 MG/L		03/09/2010	11:13	SRR
IRON	EPA 200.7	<0.0060 MG/L	N	03/09/2010	11:13	SRR
LEAD	EPA 200.7	<0.0010 MG/L	M	03/09/2010	11:13	SRR
MAGNESIUM	EPA 200.7	4.06 MG/L	J-, *, N	03/09/2010	11:13	SRR
MANGANESE	EPA 200.7	0.0295 MG/L	N	03/09/2010	11:13	SRR
MOLYBDENUM	EPA 200.7	<0.0010 MG/L		03/09/2010	11:13	SRR
MERCURY	EPA 245.1	<0.0002 MG/L		03/08/2010	18:33	SRR
NICKEL	EPA 200.7	<0.0010 MG/L		03/09/2010	11:13	SRR
SELENIUM	EPA 200.7	<0.0020 MG/L	M	03/09/2010	11:13	SRR
SILVER	EPA 200.7	<0.0010 MG/L	J-, B	03/09/2010	11:13	SRR
TIN	EPA 200.7	<0.0010 MG/L	B	03/09/2010	11:13	SRR
TITANIUM	EPA 200.7	<0.0010 MG/L		03/09/2010	11:13	SRR
THALLIUM	EPA 200.7	<0.0020 MG/L	M	03/09/2010	11:13	SRR
ZINC	EPA 200.7	<0.0020 MG/L		03/09/2010	11:13	SRR
BORON	EPA 200.7	0.0082 MG/L		03/09/2010	11:13	SRR
SOLIDS, TOTAL SUSPENDED	SM 2540,D.	<4.00 MG/L		03/08/2010	09:45	KDW

**Microbac**

KNOXVILLE DIVISION  
 505 EAST BROADWAY AVE.  
 MARYVILLE, TN 37804  
 (865) 977-1200 FAX (865) 984-8616  
 http://www.microbac.com  
 E-Mail: knoxville@microbac.com

STATE CERT ID.  
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS  
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

**CERTIFICATE OF ANALYSIS**  
**PRELIMINARY REPORT**

CITY OF KINGSTON  
 CHUCK MOORE  
 125 W. CUMBERLAND ST.  
 KINGSTON, TN 37763

Date Reported  
 Date Received 3/6/2010  
 Cust P.O.  
 Invoice No.  
 Cust # C120  
 Sample Date 3/6/2010  
 Permit No. 0000360

Work Order Number: 1003-00149

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
<b>003 FINISHED 3/6/10 0630</b>						
.....continued						
HARDNESS, TOTAL AS CaCO3	EPA 200.7;2340,B.	60.1 MG/L	J-, *	03/09/2010	11:13	SRR
<b>004 FINISHED 3/6/10 0630 DISSOLVED METALS</b>						
[ TAL METALS ]					00:00	
ALUMINUM	EPA 200.7	0.0521 MG/L	J+, B	03/09/2010	11:28	SRR
ANTIMONY	EPA 200.7	<0.0020 MG/L	M	03/09/2010	11:28	SRR
ARSENIC	EPA 200.7	<0.0010 MG/L	M	03/09/2010	11:28	SRR
BARIUM	EPA 200.7	0.0174 MG/L	B	03/09/2010	11:28	SRR
BERYLLIUM	EPA 200.7	<0.0010 MG/L		03/09/2010	11:28	SRR
CADMIUM	EPA 200.7	<0.0010 MG/L		03/09/2010	11:28	SRR
CHROMIUM	EPA 200.7	<0.0010 MG/L		03/09/2010	11:28	SRR
COBALT	EPA 200.7	<0.0010 MG/L		03/09/2010	11:28	SRR
COPPER	EPA 200.7	0.0034 MG/L		03/09/2010	11:28	SRR
IRON	EPA 200.7	0.0126 MG/L		03/09/2010	11:28	SRR
LEAD	EPA 200.7	<0.0010 MG/L	M	03/09/2010	11:28	SRR
MAGNESIUM	EPA 200.7	3.80 MG/L	J-	03/09/2010	11:28	SRR
MANGANESE	EPA 200.7	0.0253 MG/L		03/09/2010	11:28	SRR
MOLYBDENUM	EPA 200.7	<0.0010 MG/L		03/09/2010	11:28	SRR
MERCURY	EPA 245.1	<0.0002 MG/L		03/09/2010	14:16	SRR
NICKEL	EPA 200.7	<0.0010 MG/L		03/09/2010	11:28	SRR
SELENIUM	EPA 200.7	<0.0020 MG/L	M	03/09/2010	11:28	SRR
SILVER	EPA 200.7	<0.0010 MG/L	J-	03/09/2010	11:28	SRR
TIN	EPA 200.7	<0.0010 MG/L	B	03/09/2010	11:28	SRR
TITANIUM	EPA 200.7	<0.0010 MG/L		03/09/2010	11:28	SRR

® **Microbac Laboratories, Inc.**



KNOXVILLE DIVISION  
 505 EAST BROADWAY AVE.  
 MARYVILLE, TN 37804  
 (865) 977-1200 FAX (865) 984-8616  
 http://www.microbac.com  
 E-Mail: knoxville@microbac.com

STATE CERT ID.  
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS  
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

# PRELIMINARY REPORT

CERTIFICATE OF ANALYSIS

CITY OF KINGSTON  
 CHUCK MOORE  
 125 W. CUMBERLAND ST.  
 KINGSTON, TN 37763

Date Reported  
 Date Received 3/6/2010  
 Cust P.O.  
 Invoice No.  
 Cust # C120  
 Sample Date 3/6/2010  
 Permit No. 0000360

Work Order Number: 1003-00149

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
<b>004 FINISHED 3/6/10 0630 DISSOLVED METALS</b>						
.....continued						
THALLIUM	EPA 200.7	<0.0020 MG/L	M	03/09/2010	11:28	SRR
ZINC	EPA 200.7	0.0051 MG/L		03/09/2010	11:28	SRR
BORON	EPA 200.7	0.0143 MG/L		03/09/2010	11:28	SRR
SILICA (SiO2)	EPA 200.7	6.00 MG/L		03/09/2010	11:28	SRR

**M= THESE SAMPLES ARE REPORTED BY METHOD 200.7 FOR INFORMATIONAL PURPOSES TO PROVIDE QUICKER REPORTING. WHILE THESE REPORTED NUMBERS ARE CONSIDERED ACCURATE, TDEC APPROVED METHODS (EITHER 200.8 OR 200.9) ARE ALSO BEING ANALYZED AS VERIFICATION AND THIS REPORT WILL BE MODIFIED TO REFLECT THE METHOD CHANGE WHEN COMPLETE.**

RESPECTFULLY SUBMITTED: \_\_\_\_\_

MICROBAC LABORATORIES, INC.

*Thank you for your business. We invite your feedback on our level of service to you. Please contact the Laboratory Director, James Nokes, at 865-977-1200, the COO, Robert Morgan, at rmorgan@microbac.com or the President, James Nokes, at jnokes@microbac.com with any comments or suggestions.*



® **Microbac Laboratories, Inc.**

**Microbac**

KNOXVILLE DIVISION  
 505 EAST BROADWAY AVE.  
 MARYVILLE, TN 37804  
 (865) 977-1200 FAX (865) 984-8616  
 http://www.microbac.com  
 E-Mail: knoxville@microbac.com

STATE CERT ID.  
 TN 02017

CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS  
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

**CERTIFICATE OF ANALYSIS**  
**PRELIMINARY REPORT**

CITY OF KINGSTON  
 CHUCK MOORE  
 125 W. CUMBERLAND ST.  
 KINGSTON, TN 37763

Date Reported  
 Date Received 3/6/2010  
 Cust P.O.  
 Invoice No.  
 Cust # C120  
 Sample Date 3/6/2010  
 Permit No. 0000360

Work Order Number: 1003-00149

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
------	--------	--------	------	------	------	------

As regulatory limits change frequently, Microbac advises the recipient of this report to confirm such limits with the appropriate Federal, state, or local authorities before acting in reliance on the regulatory limits provided.

Microbac Laboratories, Inc. cannot guarantee the confidentiality of any facsimile or e-mail transmittal. The information in this communication is intended for the exclusive use of the addressee. If you are not the intended recipient, you are notified that any disclosure, copying, distributing, or the taking of any action in reliance on the contents of this information is strictly prohibited. If you received this transmission in error, please notify us immediately.

**QUALIFIER DEFINITIONS:**

- B = Detected in the associated Method Blank
- C = As Tons CaCO3, equivalent per 1,000 tons material
- D = Surrogate recoveries not calculated due to matrix interference and resulting sample dilution
- E1 = Elevated detection limits due to sample matrix interference
- E2 = Elevated detection limits due to high analyte concentration
- H = Analyte was prepared and/or analyzed outside of the analytical method holding time
- I = Spike recovery outside control limits due to sample matrix interference or high analyte concentration
- J = The result is an estimated quantity. The associated numerical value is the approximate concentration of the analyte in the sample
- J+ = The result is an estimated quantity, but the result may be biased high
- J- = The result is an estimated quantity, but the result may be biased low
- UJ = The analyte was analyzed for, but was not detected. The reported quantitation limit is approximate and may be inaccurate or imprecise
- K = Analyte concentration estimated due to sample matrix interference and/or high analyte concentration interference
- L1 = Liquid portion of dual phase sample analyzed only
- L2 = Solid portion of dual phase sample analyzed only
- M = Miscellaneous (see entry below analytical results)
- N = Analyte acceptable but matrix spike/matrix spike duplicate outside accepted recovery criteria
- \* = Matrix Spike/Matrix Spike Duplicate RPD is outside acceptable limits
- P = Sample received improperly preserved
- R = Relative Percent Duplicate (RPD) outside accepted recovery limits
- S1 = Spike recovery outside recovery limits
- S2 = Surrogate recovery outside of control limits. The data was accepted based on the valid recovery of remaining surrogate.
- U = Undetected
- V = Elevated reporting limits due to insufficient sample volume
- W = Results reports on dry weight basis
- Z - The parameter is considered a field analysis with an immediate to 15 minute holding time. Laboratory analysis is confirmatory in nature and is performed outside the preferred holding time window.

**ABBREVIATIONS:**

- TNTC = Too Numerous To Count
- MG/KG = Milligrams per Kilogram (PPM)
- UG/L = Micrograms per Liter (PPB)
- CFU = Colony Forming Unit



® **Microbac Laboratories, Inc.**

KNOXVILLE DIVISION  
 505 EAST BROADWAY AVE.  
 MARYVILLE, TN 37804  
 (865) 977-1200 FAX (865) 984-8616  
 http://www.microbac.com  
 E-Mail: knoxville@microbac.com

STATE CERT ID.

TN 02017



CHEMISTRY · MICROBIOLOGY · FOOD SAFETY · CONSUMER PRODUCTS  
 WATER · AIR · WASTES · FOOD · PHARMACEUTICALS · NUTRACEUTICALS

**CERTIFICATE OF ANALYSIS**  
**PRELIMINARY REPORT**

CITY OF KINGSTON  
 CHUCK MOORE  
 125 W. CUMBERLAND ST.  
 KINGSTON, TN 37763

Date Reported  
 Date Received 3/6/2010  
 Cust P.O.  
 Invoice No.  
 Cust # C120  
 Sample Date 3/6/2010  
 Permit No. 0000360

Work Order Number: 1003-00149

Subject: KINGSTON WTP RAW AND FINISHED WATER SAMPLES

Test	Method	Result	Qual	Date	Time	Tech
------	--------	--------	------	------	------	------

